



## Business Registration – Building Inspection Checklist

The following items outline the primary areas staff will review. This list serves as a general guide; additional corrections may be identified during the inspection, which could delay the issuance of the business registration.

- Proper address posted on building at left top corner.
  - *International Building Code 502.1 (2021)*
- ADA parking marked and proper signs posted.
  - *International Building Code 1106.2 and 1112.1 (2021)*
- Egress to front door is ADA compliant.
  - *International Building Code 1010.1 (2021)*
- Lever handles on all doors of the building or space inspected.
  - *International Building Code 1010.2.2 (2021)*
- Interior tactile signage (braille) shall be at 48” maximum height on all signs.
  - *Accessible and Usable Buildings and Facilities, ICC/ANSI A117.1 (2017)*
- Bathrooms shall be ADA compliant.
  - *Accessible and Usable Buildings and Facilities, ICC/ANSI A117.1 (2017)B*